



JEFFERSON COUNTY WATER AND SEWER DISTRICT

2019 Drinking Water Consumer Confidence Report *For Service Areas M, PHKE, and B-1*

Introduction

The Jefferson County Water and Sewer District (JCWSD) has prepared the following report to provide information to you, the consumer, on the quality of our drinking water. Included within this report is general health information, water quality test results, how to participate in decisions concerning your drinking water and water system contacts.

License to Operate (LTO) Status

We have a current, unconditional license to operate our water system.

Source Water Information

The JCWSD does not own a water treatment plant. Therefore, it must purchase all the water it delivers to its customers from various suppliers. The vast network of pipelines, storage tanks, and booster pump stations used to distribute water by the JCWSD are divided into different service areas. The table below lists the different service areas and corresponding supplier.

SERVICE AREA	SUPPLIER
<i>B-1, M, PHKE</i>	<i>City of Toronto Water Department</i>
O, Overlook Hills Subdivision	City of Toronto Water Department
J, Sunshine Park, Jefferson Heights Area	City of Steubenville and Mingo Junction Water Departments
A, New Alexandria, CR 19, SR 152, Piney Fork, State Route 152, Smithfield	Brilliant Water and Sewer District
G1 & G2, Rayland Area, SR 150	Village of Tiltonsville Water and Sewer Department

The source of water for the City of Toronto Water Department is the Ohio River at mile mark 59.2, which is a surface water source. The Ohio EPA has conducted a Source Water Assessment of this source. For information on how to obtain a copy of this report, please visit Ohio EPA's Source Water Assessment and Protection Program Web page at <http://www.epa.state.oh.us/ddagw/pdu/swap.html> or contact the Jefferson County Water and Sewer District at 740-283-8577.

Source Water assessment and its availability

"All surface waters are considered to be susceptible to contamination. By their nature surface waters are accessible and can be readily contaminated by pathogens and chemicals, with relatively short travel times from the source to the intake. Based on the information compiled for this assessment, the Toronto source water is considered highly susceptible to contamination [from municipal waste water treatment discharges, industrial waste water discharges, home sewage disposal system discharges, air contamination deposition, combined sewer overflows, runoff from urban, residential, mining, and agricultural areas, oil and gas production and transportation, and accidental releases and spills from rail and vehicular traffic as well as from commercial shipping operations and recreational boating]. It is important to note that this

assessment is based on available data, and therefore may not reflect current conditions in all cases. Water quality, land uses and other activities that are potential sources of contamination may change with time. While the source water for Toronto is considered susceptible to contamination, historically, the Toronto Public Water System has effectively treated this source water to meet drinking water quality standards"

What are the sources of contamination to drinking water

The sources of both tap water and bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include: (A) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; (B) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; (C) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses; (D) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems; (E) radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by the public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791)

Who needs to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk for infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

About your drinking water

The EPA requires regular sampling to ensure drinking water safety. The JCWSD and the City of Toronto Water Department conducted sampling for bacteria, inorganic, and volatile organic contaminants during 2019. The Ohio EPA requires us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently, therefore some of the results may predate 2019.

Listed below is information on those contaminants that were found in the JCWSD Water System as the result of monitoring by the City of Toronto Water Department and the JCWSD. (Contaminants sampled by the JCWSD are marked with an *.)

TABLE OF DETECTED CONTAMINANTS

Contaminants (Units)	MCLG	MCL	Level Found	Range of Detections	Violation	Sample Year	Typical Source of Contaminants
Total Organic Carbon (%Removal)	NA	TT	1.12	1.12-1.66	No	2019	Naturally present in the environment
<p><i>The value reported under "Level Found" for Total Organic Carbon (TOC) is the lowest ratio between percent of TOC actually removed to the percentage of TOC required to be removed. A value of greater than one (1) indicates that the water system is in compliance with TOC removal requirements. A value of less than one (1) indicates a violation of the TOC removal requirements.</i></p>							
Bacteriological							
Turbidity (NTU)	NA	TT	0.03	0.03-0.06	No	2019	Soil Runoff
Turbidity (% Meeting Standard)	NA	TT	100	100	No	2019	Soil Runoff
Inorganic Contaminants							
Nitrate (ppm)	10	10	1.22	0.67-1.22	No	2019	Runoff from fertilizer use; Erosion of natural deposits
Barium (ppm)	2	2	0.033	NA	No	2019	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	1.04	0.95-1.04	No	2019	Water Additive which promotes strong teeth
Disinfection By-Products							
TTHMs (Total Trihalomethanes) (ppb) *	NA	80	66.175	16.6-102	No	2019	By-product of drinking water disinfection
HAA5s (Haloacetic Acids) (ppb) *	NA	60	22.2	8.4-32.6	No	2019	By-product of drinking water disinfection
Residual Disinfectants							
Chlorine (as CL ₂) (ppm) *	MRDLG= 4	MRDL= 4	1.09	0.94-1.24	No	2019	Water additive used to control microbes
Lead and Copper *							
Contaminants (units)	Action Level (AL)	Individual Results over the AL	90% of test levels were less than	Violation	Year Sampled	Typical source of Contaminants	

Lead (ppb) *	15 ppb	0	0.0	No	2017	Corrosion of household plumbing systems; Erosion of natural deposits
	0 out of 20 samples were found to have lead levels in excess of the lead action level of 15 ppb.					
Copper (ppm) *	1.3 ppm	NA	0.0	No	2017	Corrosion of household plumbing systems; Erosion of natural deposits
	0 out of 20 samples were found to have copper levels in excess of the copper action level of 1.3 ppm.					

Revised Total Coliform Rule (RTCR) Information

All water systems were required to begin compliance with a new rule, the Revised Total Coliform Rule, beginning April 1, 2016. The new rule maintains the purpose to protect public health by insuring the integrity of the drinking water distribution system and monitoring for the presence of total coliform bacteria, which includes E. coli bacteria. The USEPA anticipates greater public health protection under the new rule, as it requires water systems that are vulnerable to microbial contamination to identify and fix problems. As a result, under the new rule there is no longer a maximum contaminant level violation for multiple total coliform detections. Instead, the new rule requires water systems that exceed a specified frequency of total coliform occurrences to conduct an assessment to determine if any significant deficiencies exist. If found, these must be corrected by the Public Water System (PWS).

Nitrate Educational Information

Nitrate in drinking water at levels above 10 ppm is a health risk for infants less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The JCWSD is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Turbidity

Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of our filtration system. The turbidity limit set by the EPA is 0.3 NTU in 95% of the daily samples and shall not exceed 1 NTU at any time. As reported above, the City of Toronto highest recorded turbidity result for 2019 was 0.06 NTU and lowest monthly percentage of samples meeting the turbidity limits was 100%.

How do I participate in decisions concerning my drinking water?

Public participation and comment are encouraged at regular meetings of the Jefferson County Board of Commissioners which meets every Thursday morning at 9:00 A.M. at 301 Market Street, Steubenville, Ohio 43952.

For help obtaining more information on your drinking water contact Michael S. Eroshevich of the JCWSD at (740) 283-8577 or via email at meroshevich@jcwatersewer.com.

Definitions of some terms contained within this report

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below, which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant levels (MCL): The highest level of contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Parts per Million (ppms) or Milligrams per Liter (mg/L) are units of measure for concentration of a contaminant. A part per million corresponds to one second in a little over 11.5 days.

Parts per Billion (ppbs) or Micrograms per Liter ($\mu\text{g/L}$) are units of measure for concentration of a contaminant. A part per billion corresponds to one second in 31.7 years.

Action Level (AL): The concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

The “<” symbol: A symbol which means less than. (A result of < 5 means that the lowest level that could be detected was 5 and the contaminant in that sample was not detected.)

The “>” symbol: A symbol which means “greater than.”